

- Ⓓ Anschluss **ausschließlich** durch ausgebildete Elektro-Fachkräfte.
- Ⓔ Electrical connection is to be made by trained electrical specialists **only**.
- Ⓕ Le branchement doit **uniquement** être effectué par des professionnels.
- Ⓙ Il collegamento deve essere eseguito **solo** da elettricisti specializzati.
- ⒺS La conexión **sólo** debe ser realizada por electricistas debidamente formados.
- ⒾT A ligação deve ser feita **exclusivamente** por profissional elétrico especializado.
- Ⓝ De aansluiting mag **enkel** gebeuren door erkende vakmensen.
- Ⓒ Pripojení smí **provádět** pouze kvalifikovaný personál.
- ⒾL Podłączenie **wyłącznie** przez specjalistów-elektryków.
- Ⓕ Liittäminen kuuluu **ainoastaan** koulutettujen sähköalan ammattilaisten tehtäviin.
- ⒿU Подключение проводится только специалистами-электриком.
- Ⓙ Bağlantı **sadece** eğitimli elektrik teknisyenleri tarafından yapılmalıdır.
- ⒸN 布线需由专业电工执行



239 480 55	24 V=, ≤ 75 mA
239 481 55	24 V=, ≤ 75 mA
239 483 55	24 V=, ≤ 75 mA



1
1a - 239 480 55
1b - 239 481 55, 239 483 55







Tabelle 1, table 1, tableau 1

X1	X2	X3	X4	X5	Colour
		24V DC	nc	COM	OFF
		24V DC	nc	COM	RD
	24V DC	24V DC	nc	COM	GN
	24V DC	24V DC	nc	COM	YE
24V DC			nc	COM	BU
24V DC	24V DC	24V DC	nc	COM	WH